

Approved M. J. Kelly Not approved _____
Inspected by M. J. Kelly Date 6-1-92
Sanitarian or Health Officer

Date 5-29-92
Permit No. 2092

CARBON COUNTY HEALTH DEPARTMENT

INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT APPLICATION

Steve York at Palisades Basin Ranches
Lot Size 1.7 Acres Owner Address Lot # 30
Unit House House, Trailer, Etc. Number of bedrooms 3
Maximum ground water depth during high water is 6 ft. from surface. Depth to Bedrock 6 ft.
Water percolation rate is per sanitary restrictions Multiples Per Inch
DISPOSAL SYSTEM:
Septic tank 1,000 Gal. Length drainfield 165' 0" Pit _____
All disposal to septic tank Bypass _____ Garbage Disp. _____ Dishwasher _____
Distance from septic tank to: Foundation 50', Well 100', Nearest property line 100'
canal, stream, lake, etc. 100'
Distance from drainfield to: Foundation 70', well 100', Nearest property line 100'
canal, stream, lake, etc. 100'

SKETCH PROPOSED DISPOSAL SYSTEM (include unit, well, stream, lake, etc. - neighbors well disposal system if in close proximity) well
A minimum 24 hour notice is required to perform an on-site inspection.



APPLICATION FEE : NEW INSTALLATION \$25.00
EXISTING \$ 5.00

APPLICANT Steve York by Lisa Hudak
INSTALLATION DATE 5/29/92

Contractor Hudak Const Address Red Lodge, MT
(See Reverse for Comments)

Approved M. J. Kelly Not approved _____
Inspected by M. J. Kelly Date 6-1-92
Sanitarian or Health Officer


Date 5-29-92
Permit No. 2092

CARBON COUNTY HEALTH DEPARTMENT

INDIVIDUAL SEWAGE DISPOSAL INSTALLATION PERMIT

Steve York at Red Lodge
Lot Size 1.7 Acres Owner Address Palisades Basin Ranches Lot # 30
Unit House House, Trailer, Etc. Number of bedrooms 3
Maximum ground water depth during high water is 6 ft. from surface. Depth to Bedrock 6 ft.
Water percolation rate is per sanitary restrictions Multiples Per Inch
DISPOSAL SYSTEM:
Septic tank 1,000 Gal. Length drainfield 165' 0" Pit _____
All disposal to septic tank Bypass _____ Garbage Disp. _____ Dishwasher _____
Distance from septic tank to: Foundation 50', Well 100', Nearest property line 100'
canal, stream, lake, etc. 100'
Distance from drainfield to: Foundation 70', well 100', Nearest property line 100'
canal, stream, lake, etc. 100'

SKETCH PROPOSED DISPOSAL SYSTEM (include unit, well, stream, lake, etc. - neighbors well disposal system if in close proximity) well



APPLICANT Steve York by Lisa Hudak
INSTALLATION DATE 5/29/92

Contractor Hudak Const Address Red Lodge, MT

NOTE: BOTH HALVES OF THE APPLICATION MUST BE FILLED OUT TO BE CONSIDERED FOR APPROVAL. FAILURE TO DO SO WILL RESULT IN THE RETURN OF THE APPLICATION TO YOU.